

REPORT No 11351

Date of issue: September 12, 2025

Status: FINAL REPORT

ASTM E572

ANALYSIS OF STAINLESS AND ALLOY STEELS BY WAVELENGTH DISPERSIVE X-RAY FLUORESCENCE SPECTROMETRY

Program: SQ-0074

This document is issued by the Company subject to its Terms and Conditions, available on request or accessible at <https://www.ptsouthquality.com/terms-and-conditions>. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Copyright © 2024 South Quality, Buenos Aires, ARGENTINA



| | | |
|---|---|---|
| Prepared by: | Reviewed by: | Approved by: |
| Sergio Andrada Assistant Technician | Eng. Alfredo Schmidt Metallurgical expert | Eng. Emiliano Medina Quality Assurance Lead |

TABLE OF CONTENTS

| | |
|---|----------|
| 1. FOREWORD | 3 |
| 2. ORGANIZATION | 3 |
| 3. OBJECTIVE | 3 |
| 4. PARTICIPANT | 3 |
| 5. HOMOGENEITY | 4 |
| 6. SAMPLE INFORMATION | 4 |
| 7. IMAGES | 5 |
| 8. ASSIGNED VALUES | 5 |
| 9. PARTICIPANT RESULTS | 6 |
| 10. STATISTICS | 6 |
| 11. EVALUATION OF PERFORMANCE | 7 |
| 12. CONCLUSIONS | 7 |
| APPENDIX | |
| PARTICIPANT RESULTS (RESULTS FORM) | 8 |

1. FOREWORD

This report summarizes the results of the **SQ-0074** proficiency testing program on the determination of the composition of stainless and alloy steels by wavelength-dispersive X-ray fluorescence analysis. This program is conducted in a bilateral format, following the A.3.3 classification of the ISO 17043 standard ("Split-sample testing schemes").

South Quality conducted the testing program in August 2025 with the aim of assessing the laboratory's ability to competently perform the designated tests.

2. ORGANIZATION

| | |
|-----------------------|----------------------|
| Program Coordinator: | Eng. Alfredo Schmidt |
| Assistant Technician: | Sergio Andrada |
| Statistic: | Lic. Manuel Tozaki |
| Supervision: | Eng. Emiliano Medina |

3. OBJECTIVE

The objective of this proficiency testing program is to determine the composition of stainless and alloy steels, using the following standard:

| Standard |
|-----------------|
| ASTM E572: 2021 |

To verify this, stainless and alloy steels samples have been selected.

Participants in this program have not been previously informed about the expected values or value ranges of the samples they receive.

4. PARTICIPANT

| | |
|-----------------|--|
| Company: | COLUMBUS STAINLESS |
| Laboratory: | Instrument Laboratory |
| Country: | South Africa |
| Client ID: | F290 |
| Contact person: | Kebuile Moseki Lab Specialist moseki.kebuile@columbus.co.za |

5. HOMOGENEITY

Several batches were prepared identically by the staff at South Quality.

Subsequently, a homogeneity study was conducted with an ISO 17025 accredited laboratory.

The control process followed ISO Guide 35: 2017, clause 7.4.1.2. Stratified random sampling was employed, and samples were chosen using random number generation software.

The results of this test are presented below:

Size of each batch: **50 units**

Tested samples from each batch: **10 units**

| DETERMINATION | HOMOGENEITY OF RESULTS IN THE ANALYZED SAMPLES | | |
|---------------|--|---------------|---------------|
| | BATCH: LM2763 | BATCH: LM2764 | BATCH: LM2765 |
| MASS FRACTION | NO | YES | YES |

Size of each batch: **50 units**

Tested samples from each batch: **10 units**

| DETERMINATION | HOMOGENEITY OF RESULTS IN THE ANALYZED SAMPLES | | |
|---------------|--|---------------|---------------|
| | BATCH: LM3264 | BATCH: LM3265 | BATCH: LM3266 |
| MASS FRACTION | YES | YES | YES |

Samples for this program are taken from the selected batches identified as LM2765 and LM3265.

For the indicated batches, the values determined in the homogeneity study are utilized as the assigned values.

The analysis of the test data indicated that the selected samples exhibited sufficient homogeneity for the program. Therefore, the results of participants identified as outliers cannot be attributed to sample variability.


6. SAMPLE INFORMATION

The following samples were sent to be tested:

| | |
|------------------|---|
| Batch: | LM2765 |
| Sample ID: | 11 |
| Characteristics: | Alloy steel (SAE 4140) - Ø 31.7 x 15 mm |

| | |
|------------------|---|
| Batch: | LM3265 |
| Sample ID: | 21 |
| Characteristics: | Stainless steel (AISI 304) - Ø 25.4 x 20 mm |

7. IMAGES



8. ASSIGNED VALUES

| BATCH | MASS FRACTION, % (Standard deviation) | | | | | |
|--------|--|------------------|------------------|------------------|------------------|--------------------|
| | CHROMIUM | COBALT | COPPER | MANGANESE | MOLYBDENUM | NIKEL |
| LM2765 | 0.932 (0.067) | 0.006 (0.001) | 0.054 (0.004) | 0.822 (0.072) | 0.179 (0.016) | 0.0301 (0.0096) |

| BATCH | MASS FRACTION, % (Standard deviation) | | | | | |
|--------|--|--------------------|------------------|--------------------|--------------------|-------------------|
| | NIOBIUM | PHOSPHORUS | SILICON | SULFUR | TITANIUM | VANADIUM |
| LM2765 | 0.003 (0.001) | 0.0135 (0.0093) | 0.245 (0.057) | 0.0126 (0.0059) | 0.0013 (0.0004) | 0.024 (0.0009) |

Note: The participant does not report results for the sample corresponding to batch LM3265, therefore, reference values are not published.

9. PARTICIPANT RESULTS (SEE APPENDIX)

| CODE | MASS FRACTION, % | | | | | |
|-----------|------------------|--------|--------|-----------|------------|-------|
| | CHROMIUM | COBALT | COPPER | MANGANESE | MOLYBDENUM | NIKEL |
| LM2765-11 | 0.966 | 0.006 | 0.06 | 0.848 | 0.16 | 0.038 |

| CODE | MASS FRACTION, % | | | | | |
|-----------|------------------|------------|---------|--------|----------|----------|
| | NIOBIUM | PHOSPHORUS | SILICON | SULFUR | TITANIUM | VANADIUM |
| LM2765-11 | 0.002 | 0.012 | 0.279 | 0.01 | 0.0011 | 0.004 |

10. STATISTICS

The results must be treated as quantitative.

The comparison is made according B.3.1.3 of ISO 17043 and the appropriate technique is to compare participant results with the assigned values. The results can be compare using percent difference ***z score***.

$$z = \frac{x - X}{\hat{\sigma}}$$

x is the participant's result

X is the assigned value

$\hat{\sigma}$ is the standard deviation

The performance evaluation of each sample is carried out with the following criteria:

$|z| \leq 2.0$ indicates “satisfactory” performance and generates no signal;

$2.0 < |z| < 3.0$ indicates “questionable” performance and generates a warning signal;

$|z| \geq 3.0$ indicates “unsatisfactory” performance and generates an action signal;

11. EVALUATION OF PERFORMANCE

| ELEMENT | MASS FRACTION, % | | z score | PERFORMANCE RESULT |
|-------------|--------------------|----------------|---------|--------------------|
| | PARTICIPANT RESULT | ASSIGNED VALUE | | |
| CHROMIUM | 0.966 | 0.932 | 0.51 | SATISFACTORY |
| COBALT | 0.006 | 0.006 | 0.00 | SATISFACTORY |
| COPPER | 0.06 | 0.054 | 1.50 | SATISFACTORY |
| MANGANESE | 0.848 | 0.822 | 0.36 | SATISFACTORY |
| MOLYBDENUM | 0.16 | 0.179 | 1.19 | SATISFACTORY |
| NICKEL | 0.038 | 0.0301 | 0.82 | SATISFACTORY |
| NIOBIUM | 0.002 | 0.003 | 1.00 | SATISFACTORY |
| PHOSPHOROUS | 0.012 | 0.0135 | 0.16 | SATISFACTORY |
| SILICON | 0.279 | 0.245 | 0.60 | SATISFACTORY |
| SULFUR | 0.01 | 0.0126 | 0.44 | SATISFACTORY |
| TITANIUM | 0.0011 | 0.0013 | 0.50 | SATISFACTORY |
| VANADIUM | 0.004 | 0.0024 | 1.78 | SATISFACTORY |

12. CONCLUSIONS

The overall performance on this **SQ-0074** program from the participant laboratory **COLUMBUS STAINLESS - Instrument Laboratory**, is **SUFFICIENT** based on expected results.

The criteria used for the evaluation of the overall performance is the following:

- **SUFFICIENT** performance: No unsatisfactory/questionable results were obtained.
- **ALMOST SUFFICIENT** performance: No unsatisfactory results were obtained, but one questionable result was found.
- **INSUFFICIENT** performance: An unsatisfactory result or two questionable results were obtained.

APPENDIX

PARTICIPANT RESULTS

(Results form)



INSTRUCTIVE & RESULTS FORM

| | |
|---------------------|--|
| PROGRAM: | Analysis of stainless and alloy steels by wavelength dispersive x-ray fluorescence spectrometry |
| CODE: | SQ-0074 |
| VERSION: | - |
| STANDARD: | ASTM E572 |
| COORDINATOR: | Eng. Alfredo Schmidt (aschmidt@ptsouthquality.com) |

1 - General

This document is intended to be filled with the results of the **SQ-0074** program.

Results must be typed, not handwritten.

2 - Standard

ASTM E572: 2021

3 - Tests involved

| TEST |
|--|
| Determination of composition of stainless and alloy steels |

4 - Samples

| CODE | SAMPLE | QUANTITY |
|-----------|----------------------------------|----------|
| LM2765-11 | Alloy steel - Ø 31.7 x 15 mm | 1 |
| LM3265-21 | Stainless steel - Ø 25.4 x 20 mm | 1 |

5 - Notes

- a) Being a bilateral program there is no deadline to accomplish sending results.
- b) Tables in this document can be modified at will for the addition of data or observations.
- c) The samples must be kept until the end of the program, which closes with the submission of the final report.
- d) The surfaces where the tests must be carried out can be either of the two faces.
- e) Participants may improve the surface to provide a better testing surface. If this is done, the procedure must be detailed in the 'observations' box.
- f) Samples should be treated as a routine laboratory sample. All testing, recording and reporting is to be performed in accordance with ASTM E572.
- g) To review the results, sending images of the tests will be appreciated. Images can be attached at the end of this document or can be sent by email.
- h) Once this document is completed, it is requested to transform it into a pdf file and send it to the program coordinator.

6 - Test conditions

| | |
|-----------------|-----------------------|
| Procedure: | According to standard |
| Final grinding: | P180 -grit |

7 - Test results

| ELEMENT | MASS FRACTION, % | |
|-------------|------------------|-----------|
| | LM2765-11 | LM3265-21 |
| CHROMIUM | 0.966 | |
| COBALT | 0.0060 | |
| COPPER | 0.060 | |
| MANGANESE | 0.848 | |
| MOLYBDENUM | 0.160 | |
| NICKEL | 0.038 | |
| NIOBIUM | 0.0020 | |
| PHOSPHOROUS | 0.012 | |
| SILICON | 0.279 | |
| SULFUR | 0.010 | |
| TITANIUM | 0.0011 | |
| VANADIUM | 0.0040 | |

| OBSERVATIONS |
|---|
| LM3265-21: Results not reported to PT scheme, sample is too small to fit into normal cassette |

PHOTOGRAPHS

Before analysis



DSQ-012

- REV 03 -

SQ-0074

4 of 5

After analysis



----- END OF REPORT -----