

REPORT No 11168

Date of issue: July 24, 2025

Status: FINAL REPORT

IEC 60754-1

DETERMINATION OF THE HALOGEN ACID GAS CONTENT

Program: SQO-PL6 Round 10

This document is issued by the Company subject to its Terms and Conditions, available on request or accessible at <https://www.ptsouthquality.com/terms-and-conditions>. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Copyright © 2024 South Quality, Buenos Aires, ARGENTINA



Prepared by:	Reviewed by:	Approved by:
Mateo Giovanni Assistant Technician	Eng. Erika Brest Chemistry expert	Eng. Emiliano Medina Quality Assurance Lead

TABLE OF CONTENTS

1. FOREWORD	3
2. ORGANIZATION	3
3. OBJECTIVE	3
4. PARTICIPANTS	4
5. HOMOGENEITY	5
6. SAMPLE INFORMATION	5
7. IMAGES	6
8. ASSIGNED VALUES	6
9. PARTICIPANT RESULTS	7
10. STATISTICS	7
11. EVALUATION OF PERFORMANCE	8
12. CONCLUSIONS	11
 APPENDIX A	
 A1 - PARTICIPANT DATA	12
 A2 - PARTICIPANT RESULTS	12
 APPENDIX B	16

1. FOREWORD

This report summarizes the results of the **SQO-PL6 Round 10** proficiency testing program on the determination of amount of halogen acid gas emitted by burning cables. This program is carried out under a simultaneous participation format, according to the A.3.1 classification of the ISO 17043 standard ("Model 2 - Figure A.1").

South Quality conducted the testing program in May/June 2025. The aim of the program was to assess laboratory ability to competently perform the nominated tests.

2. ORGANIZATION

Program Coordinator:	Eng. Erika Brest
Assistant Technician:	Mateo Giovanni
Statistic:	Lic. Manuel Tozaki
Supervision:	Eng. Emiliano Medina

3. OBJECTIVE

The objective of this proficiency testing program is to determine the amount of halogen acid of cables.

This parameter is verified using the following standard:

Standard
IEC 60754-1: 2019

For the verification of this, cables samples have been selected.

Participants in this program have not been previously informed of the values or range of values expected from the samples they receive.

4. PARTICIPANTS

In the present round, 20 laboratories have participated with the following details:

CODE	Country	ISO 17025 Accredited	Results delivered
01	China	Yes	Yes
02	Colombia	Yes	No
03	France	Yes	Yes
04	Australia	Yes	Yes
05	Malaysia	Yes	Yes
06	Germany	No	Yes
07	France	Yes	Yes
08	Chile	No	No
09	Germany	Yes	Yes
10	South Africa	Yes	Yes
11	Italy	Yes	Yes
12	Mexico	Yes	Yes
13	Portugal	Yes	Yes
14	Argentina	No	No
15	Chile	Yes	Yes
16	England	Yes	Yes
17	Canada	Yes	Yes
18	Pakistan	No	Yes
19	Spain	Yes	Yes
20	Brazil	Yes	Yes

5. HOMOGENEITY

Several batches were prepared by South Quality personnel in an identical way.

Then, a homogeneity study was then carried out with an ISO 17025 accredited laboratory.

Control was carried out according to ISO Guide 35: 2017, clause 7.4.1.2. Stratified random sampling was applied. Samples were selected using random number generation software.

The results of this test appear below:

Size of each batch: **50 samples**

Tested samples from each batch: **15 samples**

DETERMINATION	HOMOGENEITY OF RESULTS IN THE ANALYZED SAMPLES		
	BATCH: LEM2417	BATCH: LEM2418	BATCH: LEM2419
C_m	YES	YES	YES

Size of each batch: **50 samples**

Tested samples from each batch: **15 samples**

DETERMINATION	HOMOGENEITY OF RESULTS IN THE ANALYZED SAMPLES		
	BATCH: LEM3224	BATCH: LEM3225	BATCH: LEM3226
C_m	NO	YES	YES

Samples for this program are taken from selected batches identified as LEM2419, and LEM3225.

The analysis of the test data indicated that the selected samples exhibited sufficient homogeneity for the program. Therefore, the results of participants identified as outliers cannot be attributed to sample variability.


6. SAMPLE INFORMATION

The following samples were sent for testing (Participant **Code 19**):

Batch:	LEM2419
Sample ID:	10
Characteristics:	Red single core cable - 1.5 mm ² - Length: 12 cm - 5 units

Batch:	LEM3225
Sample ID:	04
Characteristics:	Light blue single core cable - 1 mm ² - Length: 12 cm - 5 units

7. IMAGES



8. ASSIGNED VALUES

The assigned values are obtained from the results reported by all participants (**Consensus values**).

9. PARTICIPANT RESULTS

LABORATORY CODE	HALOGEN ACID GAS CONTENT - MEAN (%)	
	BATCH: LEM2419	BATCH: LEM3225
01	0.339	7.025
03	0.353	6.469
04	0.347	5.915
05	0.260	6.316
06	0.404	5.873
07	0.575	6.327
09	0.405	4.879
10	0.653	6.304
11	0.520	6.445
12	0.648	5.006
13	0.656	4.189
15	0.180	2.578
16	0.462	4.495
17	0.445	6.417
18	0.655	6.420
19	0.490	5.230
20	0.000	7.285

ASSIGNED VALUES - HALOGEN ACID GAS CONTENT			
LEM2419		LEM3225	
AVG	SD	AVG	SD
0.435	0.182	5.716	1.186

10. STATISTICS

The results must be treated as quantitative.

According B.3.1.3 of ISO 17043 the appropriate technique is to compare participant results with the assigned values. The results can be compare using **z score**.

$$z = \frac{x - X}{\hat{\sigma}}$$

x is the participant's result

X is the assigned value

$\hat{\sigma}$ is the standard deviation

The performance evaluation of each sample is carried out with the following criteria:

$|z| \leq 2.0$ indicates “satisfactory” performance and generates no signal;

$2.0 < |z| < 3.0$ indicates “questionable” performance and generates a warning signal;

$|z| \geq 3.0$ indicates “unsatisfactory” performance and generates an action signal;

11. EVALUATION OF PERFORMANCE

LABORATORY CODE	z score	
	BATCH: LEM2419	BATCH: LEM3225
01	0.53	1.10
03	0.45	0.63
04	0.48	0.17
05	0.96	0.51
06	0.17	0.13
07	0.77	0.52
09	0.16	0.71
10	1.20	0.5
11	0.47	0.61
12	1.17	0.60
13	1.21	1.29
15	1.40	2.65
16	0.15	1.03
17	0.05	0.59
18	1.21	0.59
19	0.30	0.41
20	2.39	1.32

Laboratory Code 01: The laboratory obtained **SATISFACTORY** results for both samples.

Laboratory Code 02: The laboratory has not sent the results before the deadline.

Laboratory Code 03: The laboratory obtained **SATISFACTORY** results for both samples.

Laboratory Code 04: The laboratory obtained **SATISFACTORY** results for both samples.

Laboratory Code 05: The laboratory obtained **SATISFACTORY** results for both samples.

Laboratory Code 06: The laboratory obtained **SATISFACTORY** results for both samples.

Laboratory Code 07: The laboratory obtained **SATISFACTORY** results for both samples.

Laboratory Code 08: The laboratory has not sent the results before the deadline.

Laboratory Code 09: The laboratory obtained **SATISFACTORY** results for both samples.

Laboratory Code 10: The laboratory obtained **SATISFACTORY** results for both samples.

Laboratory Code 11: The laboratory obtained **SATISFACTORY** results for both samples.

Laboratory Code 12: The laboratory obtained **SATISFACTORY** results for both samples.

Laboratory Code 13: The laboratory obtained **SATISFACTORY** results for both samples.

Laboratory Code 14: The laboratory has not sent the results before the deadline.

Laboratory Code 15: The laboratory has obtained a **QUESTIONABLE** result with the LEM3225 samples. Additionally, the laboratory has obtained a **SATISFACTORY** result with the LEM2419 samples.

Laboratory Code 16: The laboratory obtained **SATISFACTORY** results for both samples.

Laboratory Code 17: The laboratory obtained **SATISFACTORY** results for both samples.

Laboratory Code 18: The laboratory obtained **SATISFACTORY** results for both samples.

Laboratory Code 19: The laboratory obtained **SATISFACTORY** results for both samples.

Laboratory Code 20: The laboratory has obtained a **QUESTIONABLE** result with the LEM2419 samples. Additionally, the laboratory has obtained a **SATISFACTORY** result with the LEM3225 samples.

GLOBAL PERFORMANCE - SUM OF ABSOLUTE Z SCORE

POSITION	LABORATORY CODE	Z SCORE
1 st	06	0.30
2 nd	17	0.64
3 rd	04	0.65
4 th	19	0.71
5 th	09	0.87
6 th	03	1.08
6 th	11	1.08
7 th	16	1.18
8 th	07	1.29
9 th	05	1.47
10 th	01	1.63
11 th	10	1.70
12 th	12	1.77
13 th	18	1.80
14 th	13	2.50
15 th	20	3.71
16 th	15	4.05

12. CONCLUSIONS

The overall performance on this **SQO-PL6 Round 10** program from the participating laboratories, based on expected results, are the following:

- Laboratories Codes **01, 03, 04, 05, 06, 07, 09, 10, 11, 12, 13, 16, 17, 18** and **19** have obtained a **SUFFICIENT** performance according to the expected results and should not take action;
- Laboratories Codes **15**, and **20** have obtained an **ALMOST SUFFICIENT** performance according to the expected results and must evaluate if it is necessary to take corrective action.
- Laboratory Code -- has obtained an **INSUFFICIENT** performance in accordance with the expected results and must take corrective action (See Appendix B).

The criteria used for the evaluation of the overall performance is the following:

- **SUFFICIENT** performance: No unsatisfactory/questionable results obtained.
- **ALMOST SUFFICIENT** performance: No unsatisfactory results were obtained, but one questionable result was found.
- **INSUFFICIENT** performance: An unsatisfactory result or two questionable results were obtained.

APPENDIX A

A1 - PARTICIPANT DATA

Company: **CEIS**


Laboratory: Centro de Ensayos, Innovacion y Servicios SL

Country: Spain

Client ID: E455

Contact person: Martina Romero Fernández (Management System Technician)
mromero@ceis.es

A2 - PARTICIPANT RESULTS



**INSTRUCTIONS
&
RESULTS FORM**

PROGRAM:	Test on gases evolved during combustion of materials from cables - Determination of the halogen acid gas content -
CODE:	SQO-PL6
ROUND:	10
STANDARD:	IEC 60754-1
COORDINATOR:	Eng. Erika Brest (ebrest@ptsouthquality.com)

DSQ-012 - REV 05 - SQO-PL6 R10 April 2025 1 de 4

1 - General

This document is intended to be filled with the results of the **SQO-PL6** program, round 10.

Results must be typed, not handwritten.

2 - Standard

IEC 60754-1: 2011 + AMD 1: 2019

3 - Participant

CEIS Centro de Ensayos, Innovación y Servicios SL	CODE 19
------------------------------------------------------	---------

4 - Tests involved

TEST
Determination of the amount of halogen acid gas evolved during the combustion of electric cable (C_m)

5 - Samples

CODE	SAMPLE	QUANTITY
LEM2419-10	Red single core cable - 1.5 mm ² Length: 12cm	5
LEM3225-04	Light blue single core cable - 1 mm ² Length: 12cm	5

6 - Notes

- The deadline for the delivery of results is **June 13, 2025**.
- The tables in this document may be modified by the participant, if desired, to include data or observations.
- The participant must cut the five received samples and mix them thoroughly. Then, two 750 mg test portions must be prepared according to the instructions in clause 6.1 of the standard.
- To review the results, the submission of images of the tests is appreciated. These images can be attached at the end of this document or sent via email.
- Upon completion of this document, please convert it to a PDF file and send it to the program coordinator.

7 - Test results

Date:	06/06/2025
-------	------------


CONDITIONING	
Temperature (°C):	22
Relative humidity (%):	45
Time (h):	24

Reagent:	<ul style="list-style-type: none"> concentrated nitric acid: about 65 %; nitric acid, approximately 6 M; 0,1 M silver nitrate; iso-amyl alcohol; 40% weight/volume solution of ferric ammonium sulphate; 0,1 M ammonium thiocyanate solution.
Type of test apparatus (Method):	Method 2

LEM2419-10	
SAMPLE	Halogen acid gas content (%)
I	0,49
II	0,49
MEAN	0,49

LEM3225-04	
SAMPLE	Amount of halogen containing gas (%)
I	5,11
II	5,35
MEAN	5,23

PHOTOGRAPHS



DSQ-012 - REV 05 -

SQO-PL6 R10

April 2025

4 de 4

APPENDIX B

VOID

----- END OF REPORT -----