

REPORT No 11496

Date of issue: December 17, 2025

Status: FINAL REPORT

IEC 60754-2

TEST ON GASES EVOLVED DURING COMBUSTION OF MATERIALS FROM CABLES DETERMINATION OF ACIDITY (BY pH MEASUREMENT) AND CONDUCTIVITY Program: SQ-2501

This document is issued by the Company subject to its Terms and Conditions, available on request or accessible at <https://www.ptsouthquality.com/terms-and-conditions>. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Copyright © 2024 South Quality, Buenos Aires, ARGENTINA



Prepared by:	Reviewed by:	Approved by:
Mateo Giovanni Assistant Technician	Eng. Erika Brest Chemistry expert	Eng. Emiliano Medina Quality Assurance Lead

TABLE OF CONTENTS

1. FOREWORD	3
2. ORGANIZATION	3
3. OBJECTIVE	3
4. PARTICIPANT	3
5. HOMOGENEITY	4
6. SAMPLE INFORMATION	5
7. IMAGES	5
8. ASSIGNED VALUES	6
9. PARTICIPANT RESULTS	6
10. STATISTICS	7
11. EVALUATION OF PERFORMANCE	7
12. CONCLUSIONS	8
APPENDICES	
APPENDIX A - INSTRUCTIONS	9
APPENDIX B - PARTICIPANT RESULTS (TR # 296/2025)	12

1. FOREWORD

This report summarizes the results of the **SQ-2501** proficiency testing program for determining the corrosivity potential of gases emitted during the combustion of electric cables. This program is conducted in a bilateral format, following the A.3.3 classification of the ISO 17043 standard ("Split-sample testing schemes").

South Quality conducted the testing program in September 2025 with the aim of assessing the laboratory's ability to competently perform the designated tests.

2. ORGANIZATION

Program Coordinator: Eng. Erika Brest
 Assistant Technician: Mateo Giovanni
 Statistic: Lic. Manuel Tozaki
 Supervision: Eng. Emiliano Medina

3. OBJECTIVE

The objective of this proficiency testing program is to determine pH and conductivity values using the following standard:

Standard
IEC 60754-2: 2011 + AMD 1: 2019

To verify this, batches of cables have been selected.

Participants in this program have not been previously informed about the expected behavior of the samples they receive.

4. PARTICIPANT

Company: **ELECTRIC PRODUCTS CERTIFICATION INDEPENDENT BODY - OICPE**
 Laboratory: **TESTING LABORATORY FOR ELECTRICAL PRODUCTS CERTIFICATION - LICPE**
 Country: Romania
 Client ID: E478
 Contact person: Razvan Neacsu
 Quality Manager
razvan.neacsu@oicpe.ro

5. HOMOGENEITY

Several batches were prepared identically by the staff at South Quality.

Subsequently, a homogeneity study was conducted with an ISO 17025 accredited laboratory.

The control process followed ISO 33405: 2024, clauses 7.4.1.1 / 7.4.1.2. Stratified random sampling was applied, and samples were selected using random number generation software.

The results of this test are presented below:

Size of each batch: **50 units**

Tested samples from each batch: **15 units**

DETERMINATION	SHEATH - HOMOGENEITY OF RESULTS IN THE SAMPLES ANALYZED		
	BATCH: LEM1843	BATCH: LEM1844	BATCH: LEM1845
pH	YES	YES	NO
CONDUCTIVITY	YES	YES	NO

Size of each batch: **50 units**

Tested samples from each batch: **15 units**

DETERMINATION	SHEATH - HOMOGENEITY OF RESULTS IN THE SAMPLES ANALYZED		
	BATCH: LEM1916	BATCH: LEM1917	BATCH: LEM1918
pH	YES	NO	YES
CONDUCTIVITY	YES	NO	YES

The samples for this program are taken from the selected batches identified as **LEM1844** and **LEM1918**.

For the indicated batches, the values determined in the homogeneity study are utilized as the assigned values.

The analysis of the test data indicated that the selected samples exhibited sufficient homogeneity for the program. Therefore, the results of participants identified as outliers cannot be attributed to sample variability.

6. SAMPLE INFORMATION

The following samples were sent for testing:

Batch:	LEM1844
Sample ID:	05 + 27 + 46
Characteristics:	Round cable - 2 x 1.5 mm ² - 10 cm

Batch:	LEM1918
Sample ID:	12 + 26 + 49
Characteristics:	Round cable - 2 x 1.5 mm ² - 10 cm

7. IMAGES



8. ASSIGNED VALUES

BATCH: LEM1844		
PROPERTY	RESULT - AVG	SD
pH	2.72	0.09
Conductivity (µS/mm)	274.12	0.98

BATCH: LEM1918		
PROPERTY	RESULT - AVG	SD
pH	2.82	0.02
Conductivity (µS/mm)	178.89	1.15

9. PARTICIPANT RESULTS (SEE APPENDIX B)

BATCH: LEM1844	
PROPERTY	RESULT - AVG
pH	2.69
Conductivity (µS/mm)	272.9

BATCH: LEM1918	
PROPERTY	RESULT - AVG
pH	2.80
Conductivity (µS/mm)	177.5

10. STATISTICS

The results must be treated as quantitative.

For quantitative results the comparison is made according B.3.1.3 of ISO 17043 and the appropriate technique is to compare participant results with the assigned values. The results can be compare using percent difference z **score**.

$$z = \frac{x - X}{\hat{\sigma}}$$

x is the participant's result

X is the assigned value

$\hat{\sigma}$ is the standard deviation

The performance evaluation of each sample is carried out with the following criteria:

$|z| \leq 2.0$ indicates “satisfactory” performance and generates no signal;

$2.0 < |z| < 3.0$ indicates “questionable” performance and generates a warning signal;

$|z| \geq 3.0$ indicates “unsatisfactory” performance and generates an action signal;

11. EVALUATION OF PERFORMANCE

PROPERTY	BATCH: LEM1844		z score	PERFORMANCE RESULT
	PARTICIPANT RESULT	ASSIGNED VALUE		
pH	2.69	2.72	0.33	SATISFACTORY
CONDUCTIVITY (µS/mm)	272.9	274.12	1.24	SATISFACTORY

PROPERTY	BATCH: LEM1918		z score	PERFORMANCE RESULT
	PARTICIPANT RESULT	ASSIGNED VALUE		
pH	2.80	2.82	1.00	SATISFACTORY
CONDUCTIVITY (µS/mm)	177.5	178.89	1.21	SATISFACTORY

12. CONCLUSIONS

The overall performance of this **SQ-2501** program from the participant laboratory **ELECTRIC PRODUCTS CERTIFICATION INDEPENDENT BODY - OICPE - TESTING LABORATORY FOR ELECTRICAL PRODUCTS CERTIFICATION - LICPE**, is **SUFFICIENT** based on expected results.

The criteria used for evaluating the overall performance are as follows:

- **SUFFICIENT** performance: No unsatisfactory/questionable results were obtained.
- **ALMOST SUFFICIENT** performance: No unsatisfactory results were obtained, but one questionable result was found.
- **INSUFFICIENT** performance: An unsatisfactory result was obtained or two questionable results were obtained.

APPENDIX A

INSTRUCTIONS



INSTRUCTIONS

PROGRAM:	Test on gases evolved during combustion of materials from cables - Determination of acidity (by pH measurement) and conductivity -
CODE:	SQ-2501
VERSION:	-
STANDARD:	IEC 60754-2
COORDINATOR:	Eng. Erika Brest (ebrest@ptsouthquality.com)

1 - General

This document serves as a guide for managing the results of the **SQ-2501** program.

2 - Standard

IEC 60754-2: 2011 + AMD 1: 2019

3 - Tests involved

TEST
Determination of the potential corrosivity of gases evolved during the combustion of electric cables

4 - Samples

CODE	SAMPLE	QUANTITY
LEM1843-XX	Round cable - 2 x 1.5 mm ² - 10 cm	3
LEM1918-XX	Round cable - 2 x 1.5 mm ² - 10 cm	3

5 - Notes

- a) Being a bilateral program there is no deadline to accomplish sending results.
- b) The participant must submit the results using the usual report employed by their laboratory.
- c) Samples must be retained until the end of the program, which concludes with the submission of the final report.
- d) To review the results, test images would be appreciated. Images can be attached at the end of this document or sent by email.

PHOTOGRAPHS

APPENDIX B

PARTICIPANT RESULTS (TEST REPORT # 296/2025)

	OICPE ELECTRIC PRODUCTS CERTIFICATION INDEPENDENT BODY OICPE - ORGANISM INDEPENDENT PENTRU CERTIFICAREA PRODUSELOR ELECTRICE www.oicpe.ro	Splaiul Unirii 313, lot 2, parter din constructia P+4, C1-U63 030138, sector 3, Bucuresti - Romania 031 426 0970 oicpe@oicpe.ro EUID : ROONRC-J2009003946401 Nr. ONRC : J2009003946401 CUI : RO 25338954	
			

LABORATORUL DE ÎNCERCĂRI PENTRU CERTIFICAREA PRODUSELOR ELECTRICE
 Testing Laboratory for Electrical Products Certification

RAPORT DE ÎNCERCĂRI TEST REPORT

No. 296 / 27.06.2025
 Pag. 1/ 5

Copy no 1 of 2

ÎNCERCAREA SOLICITATĂ
 Required Test

PRODUSUL
 Equipment

PRODUCĂTOR
 Manufacturer

CLIENT (nume, adresă, cerere)
 Customer (name, address, order)

MANAGER LABORATOR
 Laboratory Manager

DIRECTOR TEHNIC OICPE
 OICPE Technical Director

Test on gases evolved during combustion of materials from cables
 - Determination of acidity (by pH measurement) and conductivity -
 according to IEC 60754-2:2011+AMD 1:2019

1. LEM1843 Round cable – 2 x1.5 mm² – 10 cm
 2. LEM1918 Round cable – 2 x1.5 mm² – 10 cm

Unknown

PT SOUTH QUALITY SAS
 Pareja 3981, Villa Devoto, Buenos Aires
 Argentina
 BILATERAL PT Scheme SQ-2619

Eng. Răzvan NEACȘU

Eng. Dragoș ROSMETENIUC



Rezultatele încercărilor se referă numai la produsele încercate.
 Acest document poate fi reprodus numai în întregime.

*Test results refers only to tested products.
 This document may be reproduced only in its entirety.*

LICPE Cod PG-24-F-27

Ediția din 17.02.2025

	ELECTRIC PRODUCTS CERTIFICATION INDEPENDENT BODY – OICPE	
	Testing Laboratory for Electrical Products Certification	
Test Report no. 296 / 2025		Pag. 2 / 5

PRODUCT TECHNICAL DATA:

1. LEM1843 Round cable – 2 x 1.5 mm² – 10 cm
2. LEM1918 Round cable – 2 x 1.5 mm² – 10 cm

Drum no. -----

Product sort : samples

Product

Reception date : 08.08.2025

Test period : 15 ... 26.09.2025


Sampling method : Unknown. The product was submitted by the test applicant

Number of tested products : 2 (1 and 2) with 3 samples of each one as follows:

- 1.1.LEM1843-05
- 1.2.LEM1843-48
- 1.3.LEM1843-27

and

- 2.1. LEM1918-12
- 2.2. LEM1918-46
- 2.3. LEM1918-29

Tested by	Physicist Eng. Gabriel CONSTANTINESCU	
-----------	---------------------------------------	---

		ELECTRIC PRODUCTS CERTIFICATION INDEPENDENT BODY – OICPE			
		Testing Laboratory for Electrical Products Certification		LICPE	
				Test Report no. 296 / 2025	
				Pag. 3 / 5	
Article from ND	Requirement according to IEC 60754-2:2011+AMD 1:2019	Results		Requirement fulfilling	
Test on gases evolved during combustion of materials from cables.					
Determination of acidity (by pH measurement) and conductivity.					
Test method: IEC 60754-2:2011+AMD 1:2019					
Conditioning					
- durată: minim 16 h		22 h		P	
- temperatură: (23 ± 2) °C		24 °C		P	
- umiditatea relativă: (50 ± 5) %		50 %		P	
Heating procedure					
Temperature inside the quartz tube where the nacelle containing the test specimen is located: 935+965 °C		Measured temperature: 950 °C.		P	
Temperature at the limit of the heating zone: >900 °C		Measured temperature: 912 °C		P	
Sample burning time:(30±1) min		Performed sample burning time:30 min		P	
pH and conductivity measurement		The pH and conductivity values (see Table 1.2 and 2.2) are the result of <i>n</i> (min. three) tests, performed on each material of each sample.		P	
Evaluation of the test results					
General method		The mean values and standard deviation values were determined for the results of the <i>n</i> tests (minimum three) conducted on each of the non-metallic materials in the cable structure.		P	
Weighting of values					
pH weighted value [pH']		See Test Report Table 1.1 – Test results of LEM-1844		P	
Weighted value [c'] for conductivity		Table 2.1 – Test results of LEM-1918		P	
Performance requirements					
Annex A: Recommended performance requirements in the absence of a particular specification:					
A.1 Cable weighted value					
Weighted pH value: $pH' \geq 4,3$		LEM1843-05: $pH' = 2.72 < 4.3$;		See Table 1.1	NP
		LEM1843-48: $pH' = 2.67 < 4.3$;			NP
		LEM1843-27: $pH' = 2.75 < 4.3$;			NP
Weighted conductivity value: $c' \leq 10 \mu S/mm$		LEM1918-12: $pH' = 2.87 < 4.3$;		See Table 2.1	NP
		LEM1918-46: $pH' = 2.84 < 4.3$;			NP
		LEM1918-29: $pH' = 2.91 < 4.3$;			NP
Weighted conductivity value: $c' \leq 10 \mu S/mm$		LEM1843-05: $c' = 255.84 \mu S/mm > 10 \mu S/mm$		See Table 1.1	NP
		LEM1843-48: $c' = 252.08 \mu S/mm > 10 \mu S/mm$			NP
		LEM1843-27: $c' = 258.12 \mu S/mm > 10 \mu S/mm$			NP
Weighted conductivity value: $c' \leq 10 \mu S/mm$		LEM1918-12: $c' = 144.85 \mu S/mm > 10 \mu S/mm$		See Table 2.1	NP
		LEM1918-46: $c' = 143.30 \mu S/mm > 10 \mu S/mm$			NP
		LEM1918-29: $c' = 146.41 \mu S/mm > 10 \mu S/mm$			NP
A.2 Material value					
Sheath pH value: $pH \geq 4,3$		LEM1843-05: $pH = 2.70 < 4.3$;		See Table 1.2	NP
		LEM1843-48: $pH = 2.65 < 4.3$;			NP
		LEM1843-27: $pH = 2.73 < 4.3$;			NP
Sheath pH value: $pH \geq 4,3$		LEM1918-12: $pH = 2.80 < 4.3$;		See Table 2.2	NP
		LEM1918-46: $pH = 2.77 < 4.3$;			NP
		LEM1918-29: $pH = 2.83 < 4.3$;			NP

		ELECTRIC PRODUCTS CERTIFICATION INDEPENDENT BODY – OICPE					
		Testing Laboratory for Electrical Products Certification		LICPE			
				Test Report no. 296 / 2025			
				Pag. 4 / 5			
Article from ND	Requirement according to IEC 60754-2:2011+AMD 1:2019	Results		Requirement fulfilling			
Insulation pH value: $pH \geq 4,3$		LEM1843-05: $pH = 2.82 < 4.3;$	See Table 1.2	NP	NP		
		LEM1843-48: $pH = 2.78 < 4.3;$					
		LEM1843-27: $pH = 2.85 < 4.3;$					
				LEM1918-12: $pH = 2.79 < 4.3;$	See Table 2.2	NP	NP
				LEM1918-46: $pH = 2.75 < 4.3;$			
				LEM1918-29: $pH = 2.83 < 4.3;$			
Filler pH value: $pH \geq 4,3$		LEM1843-05: no filler	-----	NA	NA		
		LEM1843-48: no filler					
		LEM1843-27: no filler					
				LEM1918-12: $pH = 2.96 < 4.3;$	See Table 2.2	NP	NP
				LEM1918-46: $pH = 2.92 < 4.3;$			
				LEM1918-29: $pH = 2.99 < 4.3;$			
Sheath conductivity value: $c \leq 10 \mu S/mm$		LEM1843-05: $c = 273.70 \mu S/mm > 10 \mu S/mm$	See Table 1.2	NP	NP		
		LEM1843-48: $c = 269.50 \mu S/mm > 10 \mu S/mm$					
		LEM1843-27: $c = 275.50 \mu S/mm > 10 \mu S/mm$					
				LEM1918-12: $c = 177.80 \mu S/mm > 10 \mu S/mm$	See Table 2.2	NP	NP
				LEM1918-46: $c = 174.50 \mu S/mm > 10 \mu S/mm$			
				LEM1918-29: $c = 180.20 \mu S/mm > 10 \mu S/mm$			
Insulation conductivity value: $c \leq 10 \mu S/mm$		LEM1843-05: $c = 175.00 \mu S/mm > 10 \mu S/mm$	See Table 1.2	NP	NP		
		LEM1843-48: $c = 172.40 \mu S/mm > 10 \mu S/mm$					
		LEM1843-27: $c = 178.30 \mu S/mm > 10 \mu S/mm$					
				LEM1918-12: $c = 356.60 \mu S/mm > 10 \mu S/mm$	See Table 2.2	NP	NP
				LEM1918-46: $c = 351.20 \mu S/mm > 10 \mu S/mm$			
				LEM1918-29: $c = 359.70 \mu S/mm > 10 \mu S/mm$			
Filler conductivity value: $c \leq 10 \mu S/mm$		LEM1843-05: no filler	-----	NA	NA		
		LEM1843-48: no filler					
		LEM1843-27: no filler					
				LEM1918-12: $c = 62.10 \mu S/mm > 10 \mu S/mm$	See Table 2.2	NP	NP
				LEM1918-46: $c = 61.60 \mu S/mm > 10 \mu S/mm$			
				LEM1918-29: $c = 62.50 \mu S/mm > 10 \mu S/mm$			

Requirement fulfilling: P – Requirement is meet, NP – the requirement is not met, NA – The requirement does not apply

Measurement uncertainties

Test Name (RI Point)	Measured/ calculated	Measuring Apparatus / Type / Series or Inventory	Calibration Certificate / Issuer	Extended uncertainty [U]	Expansion factor [k]
Determination of acidity (by measuring pH) and conductivity of gases released during combustion of materials taken from cables	Mass	Weighing machine with non-automatic operation / XT 220A / W 49027	23712-11.22 / METROMAT (LE 008)	0,0002 g	2
	Temperature conditioning	Climate Chamber / Atlas SC600MH / 58566104960010	24202-11.22 / METROMAT (LE 008)	0,5 °C	2
	Relative humidity conditioning			3,0 %	2
	temperature	Thermostatic enclosure / calcination furnace / 001/2015 with indicator BTC-9100 Serial no 130025, serie 130027	24204-11.22 / METROMAT (LE 008)	5,0 °C	2
	time	Digital Stopwatch / DELTA E 200 / M200473	001092-01.24 / METROMAT (LE 008)	5,5 s	2
	pH	pH-meter / AL 15 / 89936	04-00215-01.2024 / METRON SERV (LE 015)	0,05	2
	conductivity	Conductometer / HI8424 / 87461	01-0967-04.2024 / METRON SERV (LE 015)	2,5 %	2

Note: The assigned uncertainty is the extended uncertainty obtained by multiplying the standard uncertainty by the expansion factor $k = 2$ and has been estimated in accordance with SR ISO/IEC Guide 98-3:2010. The value of the measurand is within the designated range of values with a probability of 95,45%.

	ELECTRIC PRODUCTS CERTIFICATION INDEPENDENT BODY – OICPE		
	Testing Laboratory for Electrical Products Certification		
Test Report no. 296 / 2025			Pag. 5 / 5
Article from ND	Requirement according to IEC 60754-2:2011+AMD 1:2019	Results	Requirement fulfilling

Table 1.1 – Test results of LEM-1844

Cable Code	LEM-1844-05	LEM -1844-46	LEM-1844-27	mean	std. dev	Var.coef. [%]
weighted pH'	2.72	2.67	2.75	2.71	0.040	0.010
weighted c' (uS/mm)	255.84	252.08	258.12	255.35	3.050	0.010

Table 1.2 - Raw data of LEM-1844

sheath	LEM-1844-05	LEM -1844-46	LEM-1844-27	mean	std. dev	var.coef. [%]
w [g/m]	82.268	85.376	86.041	84.562	2.014	2.382
pH	2.70	2.65	2.73	2.69	0.040	1.501
c [us/mm]	273.700	269.500	275.500	272.900	3.079	1.128
insulation	LEM-1844-05	LEM -1844-46	LEM-1844-27	mean	std. dev	var.coef. [%]
w [g/m]	18.179	18.666	18.733	18.526	0.302	1.632
pH	2.82	2.78	2.85	2.82	0.035	1.247
c [us/mm]	175.000	172.400	178.300	175.233	2.957	1.687

Table 2.1– Test results of LEM-1918

Cable Code	LEM-1918 -12	LEM -1918 -26	LEM-1918-49	mean	std. dev	var.coef. [%]
weighted pH'	2,87	2,84	2,91	2,87	0,030	0,01
weighted c' (uS/mm)	144,85	143,30	146,41	144,85	1,550	0,01

Table 2.2- Raw data of LEM-1918

sheath	LEM-1918 -12	LEM -1918 -26	LEM-1918-49	mean	std. dev	var.coef. [%]
w [g]	28,151	28,373	29,082	28,535	0,486	1,704
pH	2,80	2,77	2,83	2,80	0,03	1,071
c [us/cm]	177,80	174,50	180,20	177,500	2,862	1,612
insulation	LEM-1918 -12	LEM -1918 -26	LEM-1918-49	mean	std. dev	var.coef. [%]
w [g]	13,015	13,12	13,173	13,103	0,08	0,614
pH	2,79	2,75	2,83	2,79	0,04	1,434
c [us/cm]	356,60	351,20	359,70	355,833	4,302	1,209
filler	LEM-1918 -12	LEM -1918 -26	LEM-1918-49	mean	std. dev	var.coef. [%]
w [g]	44,516	44,217	45,198	44,644	0,503	1,126
pH	2,96	2,92	2,99	2,96	0,035	1,188
c [us/cm]	62,10	61,60	62,50	62,067	0,451	0,727

*) The coefficients of variation did not exceed the limit of 5%.

----- END OF REPORT -----